



NOTES:

1. MOUNT FLOOD LIGHT ON POST OF THE CONTROL PANEL SUPPORT. LOCATE AT ADEQUATE HEIGHT TO LIGHT WETWELL AND VALVE VAULT AREA. PROVIDE WEATHERPROOF SWITCH.
2. MOUNT 1" BRASS HOSE BIBB ON 4" x 4" PRESSURE TREATED NO. 2 PINE, MARINE GRADE, SP-22 POST. ATTACH TO POST WITH A S.S. STRAP. SEE DETAIL XX-16.
3. REFER TO THE TOWN OF HILTON HEAD FOR OFF-SITE IMPROVEMENTS REQUIRED FOR PUMP STATIONS INCLUDING LANDSCAPING, SIDEWALK, SETBACKS, BUFFER REQUIREMENTS, ETC.
4. ACCESS HATCHES MUST INCLUDE FALL PREVENTION AND FALL ARRESTING MEASURES AND COMPLY WITH OSHA REQUIREMENTS.
5. FULL RADIO TELEMETRY IS REQUIRED AT ALL NEW PUMP STATIONS.
6. REFER TO THE SANITARY SEWER PUMP STATION SPECIFICATIONS FOR ACCEPTABLE MANUFACTURERS.

HILTON HEAD NO. 1  
PUBLIC SERVICE DISTRICT

SUBMERSIBLE PUMP STATION

APPROVED BY: XXXXXXX	DATE: Feb. 1997	DRAWING NO.  XX-5
SCALE: NTS	REVISED: Jan. 2024	